
Energy performance certificate (EPC) 34 Kingsthorpe Road HOVE BN3 5HR Energy rating Valid until: 10 July 2027 Certificate 0930-5988-0333-7020-6014 Property type B1 Offices and Workshop businesses Total floor area 189 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is A.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	26 B
If typical of the existing stock	68 C

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	5
Building emission rate (kgCO2/m2 per year)	16.32
Primary energy use (kWh/m2 per year)	95

Recommendation report

Guidance on improving the energy performance of this property can be found in the $\frac{\text{recommendation}}{\text{report (/energy-certificate/9571-4023-0833-0600-0895)}}$.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Chris Armstrong
Telephone	0113 235 0860
Email	chris.armstrong@fhpp.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

About this assessment		
Email	epc@cibsecertification.org	
Telephone	020 8772 3649	
Assessor's ID	LCEA171023	
Accreditation scheme	CIBSE Certification Limited	

Employer	Bespoke Builder Services Ltd
Employer address	Teaselwood Barn, Lamberhurst Vineyard, Furnace
	Lane, Lamberhurst, Tunbridge Wells, TN3 8LA
Assessor's declaration	The assessor is not related to the owner of the
	property.
Date of assessment	10 July 2017
Date of certificate	11 July 2017