Energy performance certificate (EPC)

MARTLETS UNIT 4&5
THE 1ST CENTRAL COUNTRY GROUND
EATON ROAD
HOVE
BN3 3AN

Energy rating

Valid until: 12 July 2031

Certificate number: 5494-1638-7567-9149-8113

Property type

B1 Offices and Workshop businesses


Total floor area 134 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is C.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:



Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	48.98
Primary energy use (kWh/m2 per year)	290

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation report</u> (/energy-certificate/1140-5719-6049-5315-8526).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Joe Panther
Telephone	0800 170 1201
Email	admin@easyepc.org

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/024201
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk
About this assessment	
Employer	EASY EPC
Employer address	12 Albion Street Brighton BN2 9NE
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	8 July 2021
Date of certificate	13 July 2021